



# MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

**H.B. FULLER CONSTRUCTION PRODUCTS, INC. OF  
ST. PAUL, MN** 1200 WILLOW LAKE BLVD.; ZIP CODE: 55110

Category:  
Cert. Scheme:

Construction Materials - Interior Adhesives, Glues, Sealants & Coatings  
VOC Emissions

Accredited  
Standards &  
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

\*Conforms  
With:

LEED v4.1 ID+C, BD+C  
(CHPS) 2019 Core Criteria EQ C6.1.1  
Criteria of MAS Certified Green® Program  
TVOC Emissions at 14-days  
low-emitting material  
adhesives & sealants  
low-emitting material  
0.5 mg/m<sup>3</sup> or less

Bracketed  
Products:

Gunther Premier Plus Mirror Mastic

Test Date:

March 13, 2020 Report No.:2000234 Certificate No.: MAS2000234

valid March 2020 to March 2021



Testing Cert. # 2925.01  
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012  
\*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>